

ANNEXURE - I

(Annexure to G.O. Ms.No.56, Home (Ser.IV) Department, Dated:26.07.2019)

Instructions to be followed for schools existing before 13.04.2009:

SELF CERTIFICATION FORM

Self Certification of Fire Safety Measures by School Management :

i) General Information for School Buildings of all categories i.e., A, B, C & D.

Sl. No.	Details	
1	Date of the opening of the school building	01-06-1986
2	Name of the applicant	M. Raju, Sheran Reddy
3	Name and address of the School	St. Martin's High School, Chintal
4	Telephone Number and email of the applicant	7013295281
5	Height of the building (in meters)	13.10 m
6	No of floors	Ground + 3 Floor
7	Abutting Road width (in meters)	12 m
8	Built-up area of each floor in Sq.Mtrs Stilt --- 802.32 Ground --- 802.32 Floor1 --- 802.32 Floor2 --- 802.32	802.32
9	Number of Staircases Staircase 1 --- 1-10 (width in meters) Staircase 2 --- 1-20 (width in meters)	3.40 Mtrs.
10	Width of each Staircase	
11	Open Spaces Front --- 10.00 (width in meters) S Side 1 --- Nil (width in meters) g Side 2 --- Nil (width in meters) n Rear --- Nil (width in meters) a	10.00 M. Public Road Public Road Public Road



Signature with date of School authority and Seal
Principal
St. Martin's High School
Chintal, Hyderabad, TS

Sl. No	Fire equipment required	Scale of fire equipment as per Norms	Required	Provided Yes/ No
1	Fire Extinguishers (IS 2190:2010)	Two 09 liters water expelling extinguishers or ABC 4 kgs fire extinguisher, for every 200 square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meter radius.		
2	Automatic Sprinkler System (IS 15105:2002). The IS standard may be downloaded from www.bis.gov.in/	To be installed in basement. If area of basement exceeds 200 square meters		

Note: For Ground +1 floor buildings, If the floor area in a single floor is more than 500 square meters and if there is only single stair case, a second stair case of 1.5 Meters width shall be provided with concrete/Metal Steel structure.

Principal
St. Martin's High School
Chintal, Medchal-Malkajgiri-37

MANAGER
Signature with date of School authority and Seal
St. Martin's High School
Chintal-37, Hyderabad, TS
Scanned by CamScanner

B) School Buildings with Ground plus two floors and less than 15 Meters in height.

Sl. No	Fire equipment required	Scale of fire equipment as per Norms	Required	Provided Yes/No
1	Fire Extinguishers (IS 2190:2010)	Two 09 liters water expelling extinguishers or ABC 4 kgs fire extinguisher, for every 200 square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meter radius.	16 Nos	Yes
2	First Aid Hose Reel (IS 884:1985)	1 No for every 1000 square meter	04 Nos	Yes
3	Terrace Tank over respective tower terrace	10000 Liters (5000 Liters additionally shall be provided if basement exceeds 200 square meters)	10000 Liter	Yes
4	Automatic Sprinkler System (IS 15105:2002) The IS standard may be downloaded from www.bis.gov.in/	To be installed in basement. If area of basement exceeds 200 square meters	-NA-	-NA-
5	Pump capacity in LPM at the terrace tank level with minimum pressure of 2.5 kg/cm ²	450 LPM (450 LPM additionally shall be provided if basement exceeds 200 square meters)	450 LPM	900 LPM
Additional Fire Safety Measures in lieu of deficiency in Setbacks.				
1	Water Shower curtain	Water Shower curtain shall be provided in all floors on the side/sides having deficiency of setback to overcome exposure hazard from fires from neighboring property.	-NA-	-NA-
2	Fire Brigade Inlet	02 Nos	-NA-	-NA-

Note: If the floor area in a single floor more than 500 square meters and if there is only single stair case, a second stair case of 1.5 Meters width shall be provided with concrete/Metal steel structure.

Signature with date of School authority and Seal

C) School Buildings with 15 Meters and above but not exceeding 24 Meters in height

Sl. No	Fire equipment required	Scale of fire equipment as per Norms	Required	Provided Yes/No
1	Fire Extinguishers (IS 2190:2010)	Two 09 liters water expelling extinguishers or ABC 4 kgs fire extinguisher, for every 200 square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meter radius.		

Principal
St. Martin's High School
Chintal, Medchal-Malkajgiri-37

MANAGER
St Martin's High School
Chintal-37.